



We create chemistry

September 30, 2019

To Whom It May Concern:

This is to certify that the MasterTop® 1234 epoxy floor system with decorative quartz aggregate and GP500 Top Coat, as supplied by BASF Corporation, was tested in September 2019 by Berkeley Analytical, Richmond, CA, in accordance with California Department of Public Health Standard Method v1.2. The results of the testing indicated that the MasterTop® 1234 system with GP500 Top Coat is compliant with the maximum allowable concentrations shown in Table 4-1 of California Department of Public Health Standard Method v1.2-2017, as required by LEED v4.

As determined by the testing mentioned above, the range of total VOCs after 14 days was $\leq 0.5\text{mg}/\text{m}^3$.

Respectfully,

LEED Administrator
BASF Corporation