## **Technical Bulletin**



## Code Compliance of Finestone Pebbletex Classic PB, Secondary Weather Barrier and Pebbletex D, D7, and D10 EIFS

IBC and IRC - 2009, 2012, 2015 and 2018

Exterior Insulation and Finish Systems have been included in the International Building Code (IBC) and International Residential Code (IRC) since the 2009 versions were published. The IBC and IRC are the basis for national and local construction regulations in the United States and abroad.

IBC Section 1408 governs the materials and construction of EIFS on commercial construction – with reference to IBC Section 2603.5 for fire performance (NFPA 285, NFPA 268, ASTM E119, etc). IRC Section R703.9 governs for EIFS on residential construction (one and two family dwellings and townhouses).

Within both the IBC and IRC, ASTM E2568 is the standard cited for EIFS performance compliance. In addition, ASTM E2273 is cited for EIFS with Drainage and ASTM E2570 is included for fluid applied water-resistive barriers.

Pebbletex Classic PB and Secondary Weather Barrier comply with the performance requirements of Section 1408 and Section 2603.5 for fire performance. They are code compliant on all types of construction under the IBC except framed walls of Type V construction in R1, R2, R3 or R4 occupancy group. Under the IRC, Classic PB and Secondary Weather Barrier are limited to use on concrete or masonry walls.

The Pebbletex D, D7 and D10 systems comply with IBC Section 1408 including the requirements for drainage performance, and Section 2603.5 for fire performance. They comply with the requirements set forth in IRC Section R703.9. The Pebbletex D, D7 and D10 systems are code compliant on all types of construction under the IBC and IRC.

The tables on the following pages provide further information regarding the compliant assemblies tested for specific requirements such as noncombustible construction.



Table 1 - Wind Load Design Pebbletex Classic PB and Secondary Weather Barrier

	FRAMING	SUBSTRATE	INS	INSULATION	
TYPE	MAXIMUM SPACING (INCH)		EPS MIN THICKNESS (INCH)	ALLOWABLE WIND LOAD (PSF)	
2x4 wood		Min $\frac{7}{16}$ " wood structural panel attached in accordance with code or $\frac{1}{2}$ " ASTM C1396 or C1177 gypsum attached with #8 x 1 $\frac{1}{4}$ " screws at 8" o.c.		30 positive 30 negative	
3 5/ <sub>8</sub> " 20 ga steel	24	Min $\frac{7}{16}$ " wood structural panel attached in accordance with code or $\frac{1}{2}$ " ASTM C1396 or C1177 gypsum attached with $\frac{4}{12}$ screws at $\frac{8}{12}$ " o.c. on edges and $\frac{12}{12}$ " o.c. in field		30 positive 23 negative	
3 %" 18 ga steel	_	Min <sup>7</sup> / <sub>16</sub> " wood structural panel attached in accordance with code or ½" ASTM C1396 or C1177 gypsum attached with #8 x 1 ¼" screws at 8" o.c. on edges and 12" o.c. in field	3/4	30 positive 30 negative	
3 %" 18 ga steel	16	Metal lath fastened through ½" ASTM C1396 or C1177 gypsum attached with #8 x 1 ¼" screws at 8" o.c.		54 positive 54 negative	
N/A	N/A	N/A Concrete or masonry		Positive limited to capacity of concrete or masonry 30 negative	

<sup>\*</sup>Framing members must be designed to resist all positive and negative transverse loads with a maximum allowable deflection of 1/240 of the span \*Above results represent failures in the framing and/or sheathing connections, not failure of the Pebbletex Classic PB or Secondary Weather Barrier

Table 2 – Wind Load Design Pebbletex D, D7 and D10 Systems

FRAMING		SUBSTRATE		INSULATION			
TYPE	MAXIMUM SPACING (INCH)		EPS MIN THICKNESS (INCH)	ATTACHMENT	ALLOWABLE WIND LOAD (PSF)		
2x4 wood	16	Min $\mathcal{V}_{16}$ " wood structural panel, attached in accordance with the code	1		27 positive 35 negative		
			2	Wind-Devil 2 plates; W series fasteners	28 positive 41 negative		
			1 1/2 (channeled)	with 5/8" penetration through sheathing, 8 fasteners per board spaced 12 inches on	52 positive 28 negative		
	24		1	center vertically and horizontally	19 positive 33 negative		
			2		19 positive 36 negative		
	16	Min ½" ASTM C1396 or C1177 gypsum, min ½6" wood - structural panel, ASTM C1325 - cement board. Attached per code	1	Wind-Devil 2 plates; wood sheathing W series fasteners with %" penetration through sheathing, 8 fasteners per board spaced 12 inches on center vertically and horizontally; gypsum or cement board	21 positive 29 negative		
₃ 5⁄k-inch-by			2	sheathing S series fasteners with 5%" penetration through studs, 12 fasteners per board spaced 8 inches on center vertically	21 positive 29 negative		
lo. 20 gage steel	24		1	Wind-Devil 2 plates; wood sheathing W series fasteners with %" penetration through sheathing, 8 fasteners per board spaced 12 inches on center vertically and horizontally; gypsum or cement board	10 positive 21 negative		
	27	-	2	sheathing S series fasteners with 5%" penetration through studs, 9 fasteners per board spaced 8 inches on center vertically	12 positive 21 negative		

<sup>\*</sup>Framing members must be designed to resist all positive and negative transverse loads with a maximum allowable deflection of 1/240 of the span

Table 3 - Assemblies for Use in IBC Types I - IV (non-combustible) Construction

FRAMING MEMBERS		INTERIOR SHEATHING			EXTERIOR SHEATHING			INSULATION		
STE MIN DEPTH (INCHES)	EL	MAX SPACING (INCHES)	TYPE1	MIN THICKNESS (INCH)	MAX FASTENER SPACING (INCHES)	TYPE	MIN THICKNESS (INCH)	MAX FASTENER SPACING (INCHES)	BOARD THICKNESS MAXIMUM (INCHES)	
PEBBLETEX AND SECONDARY WEATHER BARRIER SYSTEMS										
3 %	20	16 oc	ASTM C36 or ASTM C1396	1/2	8 oc on joints 12 oc in field	ASTM C79 or ASTM C1396 or ASTM C1177	1/2	8 oc	13	
PEBBLETEX D, D7 and D10										
3 %	20	16 oc	ASTM C36 or ASTM C1396	1/2	8 oc on joints 12 oc in field	ASTM C79 or ASTM C1396 or ASTM C1177	1/2	8 oc	4	

<sup>\*</sup>The fasteners are #6 x 1 1/4 inch long bugle head screws.

Table 3 - Assemblies for Use in IBC Types I - IV (non-combustible) Construction

FRAMING MEMBERS			INTE	INTERIOR SHEATHING			EXTERIOR SHEATHING		
STEE MIN DEPTH (INCHES)	MIN GAGE	MAX SPACING (INCHES)	ТҮРЕ	MIN THICKNESS (INCH)	MAX FASTENER SPACING (INCHES)	TYPE	MIN THICKNESS (INCH)	MAX FASTENER SPACING (INCHES)	BOARD THICKNESS MAXIMUM (INCHES)
PEBBLETEX, SECONDARY WEATHER BARRIER AND PEBBLETEX D, D7 AND D10									
3 %	18	16 oc	ASTM C36 or ASTM C1396	5/8	8 oc on joints 12 o.c. in field	ASTM C79 or ASTM C1396 or ASTM C1177	5/8	8 o.c. on joints 12 o.c. in field	4

<sup>\*</sup>The fasteners are #6 x 1 % inch long bugle head screws.

For the most current version of this literature, please visit our website at finestone.master-builders-solutions.com/en.

<sup>\*\*</sup>When applied directly to concrete or masonry, the walls may be considered noncombustible construction.

<sup>\*\*\*</sup>Openings must be framed with minimum No. 20 gage steel studs and tracks.