



We create chemistry

May 23, 2019

To Whom It May Concern:

This is to certify that a sample of MasterTop® 1851 SRS CF high-performance methacrylate-based flooring system with decorative flake broadcast, as supplied by BASF Corporation, was tested in April 2019 by Berkeley Analytical, Richmond, CA, in accordance with California Department of Public Health Standard Method v1.2. The results of the testing indicated that the MasterTop® 1851 SRS CF system is compliant with the maximum allowable concentrations shown in Table 4-1 of California Department of Public Health Standard Method v1.1-2010, as required by LEED v4.

As determined by the testing mentioned above, the range of total VOCs after 14 days was $\leq 0.5\text{mg/m}^3$.

Respectfully,

A handwritten signature in cursive script that reads "Lori A. Proops".

Lori Proops, LEED® AP
Sr. Technical Product Specialist
BASF Corporation