



Master Builders
Report No. MA 2108-1251

Cleanroom[®] Suitable Materials

MasterTop TC 943
Particle (vs. PA6 Nylon): ISO 5

FLOORING & COATING

Single product Particle Emission

Qualification Certificate

We hereby certify that the material stated above, provided by

Master Builders Solution Deutschland
GmbH
Oldenburg, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number MA 2108-1251.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
MasterTop TC 943 (gray)	vs. PA6	ISO Class: 5
Reel-on-disc test normal force: 300 N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

MA 2108-1251
Report No. first document
--
Report No. current document

Stuttgart, February 16, 2022
Place, date of first document issued
--
Place, current date

on behalf of
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA